



37104

State of New Jersey
DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER RESOURCES
TRENTON, NEW JERSEY 08625

please address reply to:
 P.O. Box 2809

MAR 11 1975

Mr. W.A. Schmidt
 National Gypsum Company
 325 Delaware Avenue
 Buffalo, New York 14202

Re: Preliminary Engineering Report
 Gold Bond Building Products
 Division of National Gypsum Company
 Millington, New Jersey

Dear Mr. Schmidt:

We have reviewed your preliminary engineering report describing the methods to modify your water usages by process changes and to close in the water system. During our visit to the plant on December 18, 1974, we discussed your proposal with Mr. Stiff and verbally approved the conceptual design of the total recycle system with the following exceptions:

1. All the lagoons shall be properly lined.
2. The design of the lagoons shall be based on a 100 year storm runoff.
3. Ditches and barricades shall be provided to route the land drainage away from the lagoons.

We hereby approve the conceptual design for the proposed facilities but with the exceptions as noted in the preceding paragraph.

Issuance of a formal permit to construct and operate will be contingent on our further review and approval of final construction plans, specifications and the final engineering report when submitted with our WP-1 application form.

Very truly yours,

William S. Beggs
 William S. Beggs
 Principal Environmental Engineer
 Passaic-Hackensack Basin
 Water Pollution Control
 Operations and Enforcement

E40:G8
 c.c. Mr. Stiff

APR 3 1975
 ENVIRONMENTAL PROTECTION
 NEW YORK, N.Y. 10001
 42-2576
 37104

ASB
 001
 0912 FV